



**Certificate of Conformity
Awarded to Klamflex Pipe Couplings (Pty) Ltd**

**Klamflex Pipe Couplings, Office: 19 Resnick Street, Fectoria, Krugersdorp, South Africa
Klamflex Pipe Couplings, Factory: 52 Fransen Street, Chamdor, Krugersdorp, South Africa**

SGS SA (Pty) Ltd certifies that the following products:

**Dismantling joints, coupling and flange adaptor for water pipelines.
Range PN 25 and PN 40 only**

Dedicated Couplings

**PN 25: 50mm – 1000mm, 25 Bar Operating pressure and 37.5 Bar Testing Pressure
PN 40: 50mm – 600mm, 40 Bar Operating pressure and 60 Bar Testing Pressure**

Dedicated Flange Adaptors

**PN 25: 50mm – 1000mm, 25 Bar Operating pressure and 37.5 Bar Testing Pressure
PN 40: 50mm – 600mm, 40 Bar Operating pressure and 60 Bar Testing Pressure**

Dismantling Joints

**PN 25: 50mm – 1000mm, 25 Bar Operating pressure and 37.5 Bar Testing Pressure
PN 40: 50mm – 600mm, 40 Bar Operating pressure and 60 Bar Testing Pressure**

Designed and produced by Klamflex (Pty) Ltd

Have been evaluated and found in conformity against the following requirements:

Materials: Flange - SANS1431

Castings – SANS 936

Bolting – SANS136

Drilling to BS4504

The above listed products are manufactured under a Certified ISO 9001-2008 Quality Management System for Design, Development and Manufacturing of Flexible Pipe Couplings and Joints. The Design and manufacturing complies with the general Provisions of the AWWA C219 code. Flange Design is based on the US Bureau of Reclamation Monogram no.30-with gasket loading

Date issued: 5/08/2016

Expiry Date: 15/09/2018

**Subject to the continued Certification to ISO 9001:2008
Quality Management Systems-Requirements**

In respect of

The Design, Development and Manufacturing of Flexible pipe Couplings and Joints

Date: 5/08/2016

This document is **Certificate Number: 2016/08/IND** general Conditions of Service printed overleaf.
The Client's attention is drawn to the **Reference EQO 0404/AIA/JHB-07-2016** notification issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

